

A Power Quality analyser and fault recorder

Model PQI-DE

- ▶ 4 x voltage, 5 x current
- ▶ 20 kHz bandwidth
- ▶ Residual current monitor RCM



1. Application

The Power Quality Analyser and Fault Recorder PQI-DE for low, medium and high voltage networks is the central component of a system with which all measurement tasks in electrical networks can be solved.

The PQI-DE can be used as a Power Quality Interface according to power quality standards such as IEC 61000-2-2 / EN 50160 or to check the technical connection guidelines such as DIN VDE AR 4110 and DIN VDE 4120 and many more. Due to the available open SCADA standard interfaces such as Modbus RTU/TCP as well as IEC 61850 with open data exchange format PQDIF (IEEE1159-3), the device can also be used as a highly accurate measurement transducer for all physically defined measured variables in 3-phase systems parallel to the continuous recording of measured values over a very long period.

In addition to the possibility of standard evaluations, the PQI-DE also has a high-speed disturbance recorder with a recording rate of 40.96kHz/10.24kHz and a 10ms TRMS effective value recorder. This allows a detailed evaluation of grid disturbances.

The PQI-DE is equipped with a fifth current input for continuous residual current monitoring (RCM). It is possible to freely program thresholds for alarms or warnings.

Modern Power Quality Analysers comply with the IEC 62586 standard, which describes the complete product feature of a Power Quality Analyser. This standard defines not only the purpose of use, the EMC environment and the environmental conditions, but also the exact measurement methods IEC 61000-4-30 Class A, in order to create a comparable and reliable basis for the end-user.

According to IEC 62586, the PQI-DE is a device of class **PQI-A-FI-H** and is therefore fully certified in external laboratories. **Power Quality Interface – Class A – Fixed Installed Measurement Device for Indoor operation in Harsh EMC environments**

The PQI-DE meets the requirements of IEC 61000-4-30:2015 Ed 3 +A1:2021 for Class A measuring instruments for 100 % of the parameters.

Parameter IEC61000-4-30 Ed. 3	Class
Power frequency	A
Magnitude of the Supply Voltage	A
Flicker	A
Supply voltage dips and swells	A
Voltage interruptions	A
Supply voltage unbalance	A
Voltage harmonics	A
Voltage interharmonics	A
Mains signalling voltage	A
Measurement aggregation intervals	A
Time-clock uncertainty	A
Flagging	A
Transient influence quantities	A

The measuring device and the development are subject to strict security requirements within the scope of the requirements in the area of *KRITIS*. In relation to these, an active patch management, encrypted communication standards as well as a User Rights Management (*URM*) via *RADIUS* are available in the device! This also includes signed firmware updates, security logging and active protection against brute force attacks. All this contributes to a secure operation in your IT environment!

2. Design

The *PQI-DE* has been developed for measurements performed within public grids as well as for recording PQ data within an industrial environment up to 690V (L-L) measurement voltage.

- No moving parts (fans, hard drives etc.)
- CAT IV
- Extensive storage capability (can be extended up to 32 GB by the user, permitting several years recording without connection to database)
- ▶ **Optional: "IEC 61000-4-7 - 2 kHz to 20kHz" (B1)**
- Frequency measurement of voltage and current according to IEC 61000-4-7 from 2 kHz to 20kHz.
- Sampling rate voltage and current 40.96kHz
- ▶ **Optional: Residual current monitor RCM (D1)**
- ▶ **Optional: "PQDIF data format" (F1)**
- Open data exchange format according to IEEE1159-3 via MMS / IEC61850 (feature P2)

2.1 Characteristics of the Power-Quality Interface *PQI-DE*

2.1.1 Technical Data

- 5-inch colour display
- Keypad for basic/direct device configuration
- 1 GB internal memory (extended up to 32 GB)
- IP54 in installed condition
- Input channel bandwidth 20 kHz
- 4 voltage inputs Accuracy < 0.1 %
- 4 current inputs
- PE current input for the detection of differential currents or currents of the ZEP (central grounding point)
- Temperature input for Pt100 and Pt1000 sensor
- Simultaneous processing of sampled and calculated voltages and currents
- Oscilloscopic voltage and current recorder sampling rate: 40.96 kHz / 10.24 kHz
- Half cycle recorder: power frequency, RMS of voltages and currents, voltage and current phasors, power recording rate: ~10 ms(50 Hz) / ~8.33 ms (60 Hz)
- Powerful recorder triggering
- Online streaming of voltages and currents at 40.96 kHz sampling rate
- Recording of power quality incidents according to DIN EN 50160; IEC 61000-2-2; -2-12; -2-4

- Power buffer for voltage interruptions of up to 2 seconds
- Spectral analysis 2 kHz...20kHz (90 frequency bands, Bandwidth = 200Hz) of voltages and currents according (IEC 61000-4-7)
- Phase of voltage and current harmonics n=2..50
- 8 digital inputs (Triggering fault records, Recording Start / Stop)
- 4 relay outputs for protection monitoring and alarming
- EDGE function - 32 freely configurable monitoring states for monitoring and triggering all measured variables - Output as binary message or via protocol
- Free of charge analysis software WinPQ lite (sold as a package)
- **Option:** Analysis of the data on a database using the WebPQ software package. Permanent communication and evaluation of the data with many devices in parallel

Communication Protocols

- MODBUS RTU & MODBUS TCP
- IEC 60870-5-104 (Option P1)
- IEC 61850 (Option P2)
- Modbus Master (Option P3)

Time synchronisation protocols

- IEEE 1344 / IRIG-B000...007
- GPS (NMEA +PPS)
- DCF77
- NTP

Interfaces

Ethernet	RJ45 (10/100 Mbit)
USB	USB 2.0 – Type C
Two RS232/RS485	switchable

Dimensions

L x B x	144 x 144 x 90 mm without terminals
Weight	1220 g

Voltage inputs

Feature	E1	E2	E3
Channels	U ₁ , U ₂ , U ₃ , U _{N/E/4}		

Electrical safety DIN EN 61010	150V CATII	300V CAT IV 600V CAT III	SELV
Input reference level	PE	PE	PE
Impedance -> PE	2 MΩ 25pF	10 MΩ 25pF	2 MΩ 50pF
Nominal input voltage U _n	100 V _{AC}	230 V _{AC}	3,25V
Full scale range (FSR)	0...120 V _{AC} L-E	0...480 V _{AC} L-E	0...5 V _{AC} L-E
Overload, permanent	150V _{AC}	600V _{AC}	10V _{AC}
Maximum crest factor @ U _{nom}	3	3	2,2
Bandwidth	DC...20 kHz		
Nominal power frequency f _{nom}	50 Hz / 60 Hz		
Frequency range of the fundamental	f _n ± 15 % 42,5..50..57,5 Hz 51,0..60..69,0 Hz		

Dip duration	±20 ms @ 10 %..100 % U _{nom}
Swell residual voltage	±0,2 % U _{nom} @ 100 %..150 % U _{nom}
Swell duration	±20 ms @ 100 %..150 % U _{nom}
Interruption duration	±20 ms @ 1 %..100 % U _{nom}
Voltage unbalance	±0,15 % @ 1 %..5 % Messwert
Mains signalling voltage (< 3 kHz)	±5% des Messwerts @ U _s = 3%..15% U _{nom} ±0,15 % U _n @ U _s = 1 %..3 % U _{nom}

Accuracy

Fundamental, r.m.s. U ₁ ≤ 150% U _{nom} 0°C ≤ TA ≤ +45°C: -25°C ≤ TA ≤ +55°C:	±0.1% v. U _{nom} ±0.2% v. U _{nom}
Fundamental, Phase U ₁ ≥ 10% U _{nom} :	±0.02°
Harmonics n = 2...50, r.m.s. U _h ≥ 1% U _{nom} : U _h < 1% U _{nom} :	±5.0% v. U _h ±0.05% v. U _{nom}
Harmonics n = 2...50, Phase U _h ≥ 1% U _{nom} :	±0.5°
Interharmonics n = 1...49, r.m.s. U _{ih} ≥ 1% U _{nom} : U _{ih} < 1% U _{nom} :	±5.0% v. U _h ±0.05% v. U _{nom}
Power frequency	±1 mHz @ 10 %...200 % U _{nom}
Flicker DIN EN 61000-4- 15:2011	Klasse F1
Dip residual voltage	±0,2 % U _{nom} @ 10 %..100 % U _{nom}

We take care of it.

Current inputs			Accuracy		
Option	C30	C31	Feature	30	C31
Channels	I1, I2, I3, IN/4		Fundamental, r.m.s.	$I_1 \geq 10\% \text{ FSR: } \pm 0.1\% \text{ v. } I_1$ $I_1 < 10\% \text{ FSR: } \pm 0.01\% \text{ v. FSR}$	$I_1 = 1\% \dots 20\% \text{ FSR: } \pm 0.5\% \text{ v. } I_1$ $I_1 < 1\% \text{ FSR: } \pm 0.005\% \text{ v. FSR}$
Electrical safety DIN EN 61010	300V CAT III				
Input type	potentialfrei		Fundamental, Phase	$I_1 \geq 10\% \text{ FSR: } \pm 0.1^\circ$	$I_1 = 1\% \dots 20\% \text{ FSR: } \pm 0.5^\circ$
Impedance	$\leq 4\text{m}\Omega$				
Nominal input current I_n	5 A_{AC}		Harmonic $n = 2 \dots 50$, r.m.s. $I_h \geq 3\% I_{nom}$: $I_h < 3\% I_{nom}$:	$\pm 5.0\% \text{ v. } I_h$ $\pm 0.15\% \text{ v. } I_{nom}$	$\pm 10\% \text{ v. } I_h$ $\pm 0.3\% \text{ v. } I_{nom}$
Full scale range (FSR)	10 A_{AC}	100 A_{AC}			
Overload capacity permanent $\leq 10\text{s}$ $\leq 1\text{s}$	20 A_{AC} 100 A_{AC} 500 A_{AC}		Harmonic $n = 2 \dots 50$, Phase $I_h \geq 3\% I_{nom}$:	$\pm 0.5^\circ$	$\pm 2.0^\circ$
Waveform	AC, any				
Maximum crest factor @ I_n	3	30	Interharmonic $n = 1 \dots 49$, r.m.s. $I_{ih} \geq 3\% I_{nom}$: $I_{ih} < 3\% I_{nom}$:	$\pm 5.0\% \text{ v. } I_{ih}$ $\pm 0.15\% \text{ v. } I_{nom}$	$\pm 10\% \text{ v. } I_{ih}$ $\pm 0.3\% \text{ v. } I_{nom}$
Bandwidth	25Hz...20kHz				
Tightening torque	2 Nm				

Feature	C40	C44	C45
Full Scale Range (FSR)	0.35V _{AC} @ 50Hz	0.50V _{AC}	±5.6V
Impedance	1MΩ	1MΩ	1MΩ
Input type	symmetrisch		
Isolation	basic (SELV)	basic (SELV)	basic (SELV)
External sensors	Rogowski coil, potential free	current clamp, potential free	Hall-Sensor, potential free
Differential overload, permanent	10V _{AC}	±15V	±15V
Common mode area	±15V	±15V	±15V
Bandwidth	25Hz...20kHz	DC...20kHz	DC...20kHz

Accuracy

Grundschwingung, r.m.s. I ₁ ≥ 10% FSR: I ₁ < 10% FSR:	±0.2% v. I ₁ ±0.02% v. FSR	±0.1% v. I ₁ ±0.01% v. FSR	±0.1% v. I ₁ ±0.01% v. FSR
Grundschwingung, Phase I ₁ ≥ 10% FSR:	±0.2°	±0.1°	±0.1°
Harmonische n = 2...50, r.m.s. I _h ≥ 1% FSR: I _h < 1% FSR:	±5.0% v. I _h ±0.05% v. FSR	±5.0% v. I _h ±0.05% v. FSR	±5.0% v. I _h ±0.05% v. FSR
Harmonische n = 2...50, Phase I _h ≥ 1% FSR:	±1.0°	±0.5°	±0.5°
Zwischenharmonische n = 1...49, r.m.s. I _{ih} ≥ 1% FSR: I _{ih} < 1% FSR:	±5.0% v. I _{ih} ±0.05% v. FSR	±5.0% v. I _{ih} ±0.05% v. FSR	±5.0% v. I _{ih} ±0.05% v. FSR

Power supply			
Feature	H1	H2	H3
AC Nominal range [V]	100...240	-	-
AC Operating range [V]	90...264	-	-
DC Nominal range [V]	120...320	24...60	48...138
DC Operating range [V]	108...350	18...75	40...160
Power consumption	≤ 10 W < 20 VA	≤ 10 W	≤ 10 W
Frequency Nominal	50...60Hz	DC	DC
Frequency Operating	40...70Hz	DC	DC
External fuse characteristics	6A B	6A B	6A B
Energy storage	2 sec	2 sec	2 sec

Storage of measured values	
Internal memory	1024 MB
SD memory card	1 GB to 32 GB

Residual current monitor (RCM)	
Nominal current	30 mA
Impedance	4 Ω
Overload capacity	5 A (1 seconds)
Resolution	24bit-ADC

We take care of it.

Binary outputs (BO)	
4 binary outputs	3 x closer 1 x changeover
Contact specification (EN60947-4-1, -5-1) : Configuration Nominal voltage Nominal current Nominal load AC1 Nominal load AC15, 230VAC Interrupting power DC1, 30/110/220 V	3 x SPST (Single Pole Single Throw) 1 x SPDT (Single Pole Double Throw) 250VAC 6 A 1500 VA 300 VA 6/0.2/0.12 A
Number of switching operations AC1	≥ 60·10 ³ electrical
Electrical Isolation	Isolated from all internal potentials

Electrical safety DIN EN 61010	300V
--------------------------------	------

Binary inputs (BI)		
Feature	M1	M2
8 binary inputs	0 V..250 V _{AC}	0 V...48 V _{DC}
Range	/V _{DC}	
— H – Level	> 35 V	> 10V
— L – Level	< 20 V	< 5V
Signal frequency	DC ... 70 Hz	DC ... 70 Hz
Input resistance	> 100 kΩ	6.8 kΩ
Electrical isolation	Optocoupler, electrically isolated	
Electrical safety DIN EN 61010	300V	

Temperature input Pt 100 / Pt 1000 / KTY– (Firmware V2.2)	
Contacting measurement sensor (software setting)	2 wire
	3 wire
	4 wire
Update rate	1 second / 1Hz
Resolution	15 Bit
Burden	1,9 kOhm
Accuracy	0.05 % FSR

Electromagnetic Compatibility	
Immunity	<ul style="list-style-type: none"> IEC 61000-6-5, environment H
Emissions	<ul style="list-style-type: none"> CISPR22 (EN 55022), class A

Electrical safety	
<ul style="list-style-type: none"> IEC 61010-1 IEC 61010-2-030 	
Protection class	1
Pollution degree	2
Overvoltage category mains supply option :	
H1	300V CAT II
H2/H3	150V CAT II
Measurement category	300V CAT IV 600V CAT III
Altitude	≤ 2000 m
IP protection class	IP54 (in installed condition)

Environmental parameters	Storage and transport	Operation
Ambient temperature: Limit range of operation	IEC 60721-3-1 / 1K5 -40 ... +70°C IEC 60721-3-2 / 2K4 -40 ... +70°C	IEC 61010 -25 ... +45°C H1 -25 ... +50°C H2/H3
Ambient temperature: Rated range of operation H1 Rated range of operation H2 /H3	---	IEC DIN EN 61010 -25 ... +45°C -25 ... +50°C
Relative humidity: 24h average No condensation or ice	5...95 %	5...95 %
Solar radiations	---	700 W/m ²
Vibration, earth tremors	IEC 60721-3-1 / 1M1 IEC 60721-3-2 / 2M1	IEC 60721-3-3 / 3M1

According to **IEC61557-12**, the PQI-DE corresponds to a PMD type III of class PMD -SD according to Table 2 (indirect current measurement, direct voltage measurement) for low voltage or PMD SS (indirect current measurement, indirect voltage measurement) in climatic category K55.

Thus a marking according to IEC61557-12 is possible for the measuring device as follows:

PMD SD / K55 / 0.2

PMD SS / K55 / 0.2


Herewith the following accuracies are given:

Measured variable	C40 / C44 / C45	C30 @ 5A	Current clamp Klasse 0.5	Current clamp Klasse 1
Active energy	0.2	0.2	< 1	< 2
Active power	0.2	0.2	< 1	< 2
Reactive energy	< 2	< 2	< 2	2
Reactive power	< 1	< 1	1	< 2
Apparent energy	0.2	0.2	< 1	< 2
Apparent power	0.2	0.2	< 1	< 2
Frequency	< 0.02			
Phase current	0.1	0.1	< 1	< 2
Measured IN	< 0.2	< 0.2	< 1	< 2
Calculated IN	0.1	0.1	< 1	< 2
Voltage	0.1			
Power factor	< 0.5	< 0.5	< 1	< 2
Flicker	5			
Dips and swells	< 0.5			
Voltage interruption	0.5			
Voltage unbalance	0.2			
Voltage harmonics	1			
Voltage THD	1			
Current unbalance	0.2	0.2	< 1	< 2
Current harmonics	1	1	< 2	2
Current THD	1	1	1	1


2.1.2 Mechanical design

The PQI-DE is used as a panel-mounted device and fulfils IP54 when installed. All connections are accessible via Phoenix terminals. Apart from the current inputs, the connections are made using plug-in terminal technology.

A TCP/IP interface (RJ 45 LAN connection) and a USB interface (type C socket) are available for communication. In addition to the internal memory of 1 GB, the device memory can be expanded by a further 32 GB via an external memory card. The memory card can also be used to easily read out measurement data from the instrument and transmit it to an evaluation PC.




Back view PQI-DE



Side view of PQI-DE

2.1.3 Terminal strip number PQI-DE




Terminal strip no.	Designation	Function	Terminal no.	cross section [mm ²]	Stripping length mm	Torque in Nm	
X1	Auxiliary voltage	U _H	L (+)	11	0.2 ... 2.5	10	0,5 ... 0,6
			L (-)	12	0.2 ... 2.5	10	0.5 ... 0.6
X1	Ground	GND	PE	13	ring terminals M4	-	0.5 ... 0.6


Terminal	Designation	Function	Terminal	cross section	Stripping	Torque in
----------	-------------	----------	----------	---------------	-----------	-----------

strip no.				no.	[mm ²]	length mm	Nm
X2	Binary input	BICOM	-	21	solid: 0.2 ... 1.5 flexible: 0.2 ... 2.5	10	0.5 ... 0.6
		BI1	+	22		10	0.5 ... 0.6
		BI2	+	23		10	0.5 ... 0.6
		BI3	+	24		10	0.5 ... 0.6
		BI4	+	25		10	0.5 ... 0.6
		BI5	+	26		10	0.5 ... 0.6
		BI6	+	27		10	0.5 ... 0.6
		BI7	+	28		10	0.5 ... 0.6
		BI8	+	29		10	0.5 ... 0.6
X3	Phase voltage L1 (AC)	U ₁	L1	31	0.2 ... 2.5	10	0.5 ... 0.6
	Phase voltage L2 (AC)	U ₂	L2	32		10	0.5 ... 0.6
	Phase voltage L3 (AC)	U ₃	L3	33		10	0.5 ... 0.6
	Neutral point voltage (AC)	U ₄	N/E	34		10	0.5 ... 0.6
X4	PT100/Pt1000/KTY Temperature input	T1	RTDOU+	41	0.14 ... 0.5	10	0.5 ... 0.6
			RTDIN+	42		10	0.5 ... 0.6
			RTDIN-	43		10	0.5 ... 0.6
			RTDOU-	44		10	0.5 ... 0.6
X5	Binary output	R1	NO	51	solid: 0.2 ... 1.5 flexible: 0.2 ... 2.5	10	0.5 ... 0.6
			NC	52		10	0.5 ... 0.6
			Pol	53		10	0.5 ... 0.6
		R2	NO (+)	54		10	0.5 ... 0.6
			Pol (-)	55		10	0.5 ... 0.6
		R3	NO (+)	56		10	0.5 ... 0.6
			Pol (-)	57		10	0.5 ... 0.6
		R4	NO (+)	58		10	0.5 ... 0.6
			Pol (-)	59		10	0.5 ... 0.6
		X6	Phase current L1	I1		S1 (K) S2 (L)	61 62
Phase current L2	I2		S1 (K) S2 (L)	63 64		0.5 ... 0.8	
Phase current L3	I3		S1 (K) S2 (L)	65 66		0.5 ... 0.8	
Neutral / sum current	I4		S1 (K) S2 (L)	67 68		0.5 ... 0.8	
X9	RCM - Input	I5	+	91	solid: 0.34... 2.5 flexible: 0.2 ... 2.5	10	0.5 ... 0.6
			-	92		10	0.5 ... 0.6


2.1.4 Dimensions




Front view PQI-DE



Back View PQI-DE



Panel cut-out PQI-DE



Right view PQI-DE

The maximum panel thickness for PQI-DE installation is 8mm.

2.1.5 Colour display

The device's 5-inch colour display provides information about the correct connection of the measuring cables and transmitter and shows online data of voltage, current, total harmonic distortion (THD), harmonics up to 9 kHz power and energy. A kind of drag pointer function informs about the maximum current of the last day, the last week, the last month and absolute since the last reset of the extreme value.

The number of Power Quality events, oscilloscope and RMS fault records for the last day, week and month appear on the display.



The commissioning and parameterisation of the PQI-DE can be carried out very easily via the keypad and the display of the device or via the WinPQ Lite software.

2.2 Measurement / Functions

PQI-DE complies with the automatic event detection and measurement standards, which are:

EN50160:2021/ IEC61000-2-2 / IEC61000-2-12 / IEC61000-2-4 (Class 1; 2; 3) / NRS048 / IEEE519 / IEC61000-4-30 Class A Ed 3/ IEC 61000-4-7 / IEC61000-4-15 / IEEE1159-3

Continuous Recording:

Five fixed and two variable measurement time intervals are available for continuous recording:

10/12 T (200ms), 1 sec, n*sec, 150/180 T (3sec), n*min, 10 min, 2 h

Time Interval Voltage	10/ 12T	150/ 180T	10 min	2 h	1 s	10s	N* s	N* min
PQDIF			✓(*)	✓(*)		✓		
Power frequency	✓	✓	✓	✓	✓	✓	✓	✓
Extremes, standard deviation of power frequency (10s)			✓			✓		
r.m.s. values (IEC61000-4-30)	✓	✓	✓	✓	✓		✓	✓
Extremes, standard deviation of T/2-values			✓					
Underdeviation [%] , Overdeviation [%] (IEC61000-4-30)	✓	✓	✓	✓				
Harmonic subgroups n= 0..50 (IEC61000-4-7)	✓	✓	✓	✓				
Maximum values of 10/12 T harmonic subgroups n = 2..50			✓					
Interharmonic subgroups n=0..49 (IEC61000-4-7)	✓	✓	✓	✓				
Total Harmonic Distortion (THDS) (IEC61000-4-7)	✓	✓	✓	✓	✓		✓	✓
Partial Weighted Harmonic Distortion (PWHHD)	✓	✓	✓	✓	✓		✓	✓
Unbalance, negative-/positive sequence, sequence sign	✓	✓	✓	✓	✓		✓	✓
Unbalance, zero-/positive sequence	✓	✓	✓	✓	✓		✓	✓
Positive-, negative-, zero sequence phasors	✓	✓	✓	✓	✓		✓	✓
Phasors (fundamental)	✓	✓	✓	✓	✓		✓	✓
Flicker (IEC61000-4-15)			✓	✓				
Instant flicker (IEC61000-4-15)	✓		✓					
Mains signalling voltages [%] (IEC61000-4-30)	✓	✓						
Phase angle (zero crossings) of phase voltage harmonics n=2..50 to fundamental of reference voltage	✓	✓	✓	✓				
Frequency bands 1..90 , 2kHz..20kHz, r.m.s. (IEC61000-4-7)			✓	✓	✓		✓	✓

(*) The following restrictions apply to PQDIF:

- 10 min and 2 h: No phase angles of voltage and current harmonics
- 2 h: No Supraharmonics >9kHz

Time Interval Current	10/ 12T	150 /180T	10 min	2 h	1 s	N* s	N* min
PQDIF			✓(*)	✓(*)			
r.m.s. values	✓	✓	✓	✓	✓	✓	✓
Extremes of T/2-values			✓				
Harmonic subgroups n= 0..50 (IEC61000-4-7)	✓	✓	✓	✓			
Maximum values of 10/12 T harmonic subgroups n = 2..50			✓				
Interharmonic subgroups n=0..49 (IEC61000-4-7)	✓	✓	✓	✓			
Total Harmonic Distortion (THDS) (IEC61000-4-7)	✓	✓	✓	✓	✓	✓	✓
Total Harmonic Currents	✓	✓	✓	✓	✓	✓	✓
Partial Weighted Harmonic Distortion (PWHD)	✓	✓	✓	✓	✓	✓	✓
Partial Odd Harmonic Currents (PHC)	✓	✓	✓	✓	✓	✓	✓
K-Factors	✓	✓	✓	✓	✓	✓	✓
Unbalance, negative/positive sequence , sequence sign	✓	✓	✓	✓	✓	✓	✓
Unbalance, zero/positive sequence	✓	✓	✓	✓	✓	✓	✓
Positive-, negative-, zero sequence phasors	✓	✓	✓	✓	✓	✓	✓
Phasors (fundamental)	✓	✓	✓	✓	✓	✓	✓
Phase angle (zero crossings) of current harmonics n=2..50 to fundamental of reference voltage	✓	✓	✓	✓			
Frequency bands 1..35 , 2kHz..9kHz, r.m.s. (IEC61000-4-7)			✓	✓	✓	✓	✓

Time Interval Energy	10 min	2 h	1 s	N* s	N* min
PQDIF	✓	✓			
Active energy, phase	✓	✓	✓	✓	✓
Active energy, total	✓	✓	✓	✓	✓
Exported active energy, phase	✓	✓	✓	✓	✓
Exported active energy, total	✓	✓	✓	✓	✓
Imported active energy, phase	✓	✓	✓	✓	✓
Imported active energy, total	✓	✓	✓	✓	✓
Reactive energy (inductive), phase	✓	✓	✓	✓	✓
Reactive energy (inductive), total	✓	✓	✓	✓	✓
Exported reactive energy (inductive), phase	✓	✓	✓	✓	✓
Exported reactive energy (inductive), total	✓	✓	✓	✓	✓
Imported reactive energy (inductive), phase	✓	✓	✓	✓	✓
Imported reactive energy (inductive), total	✓	✓	✓	✓	✓
Total apparent energies, phase& total	✓	✓	✓	✓	✓
Export apparent energies, phase & total	✓	✓	✓	✓	✓
Import apparent energies, phase & total	✓	✓	✓	✓	✓
Distortion reactive energies, phase & total	✓	✓	✓	✓	✓

Time Interval Power	10 min	2 h	1 s	N* s	N* min
PQDIF	✓	✓			
Active power, phase	✓	✓	✓	✓	✓
Active power, total	✓	✓	✓	✓	✓
Active power extremes	✓				
Reactive power, phase	✓	✓	✓	✓	✓
Reactive power, total	✓	✓	✓	✓	✓
Reactive power extremes	✓				
Apparent power, phase	✓	✓	✓	✓	✓
Apparent power, total	✓	✓	✓	✓	✓
Fundamental active power, phase	✓	✓	✓	✓	✓
Fundamental active power, total	✓	✓	✓	✓	✓
Fundamental reactive power, phase	✓	✓	✓	✓	✓
Fundamental reactive power (displacement), total	✓	✓	✓	✓	✓
Fundamental apparent power, phase	✓	✓	✓	✓	✓
Phase angle of fundamental apparent power, phase	✓	✓	✓	✓	✓
Fundamental apparent power, total	✓	✓	✓	✓	✓
Phase angle of fundamental apparent power, total	✓	✓	✓	✓	✓
Reactive distortion power, phase	✓	✓	✓	✓	✓
Reactive distortion power, total	✓	✓	✓	✓	✓
Active power factors, phase, total	✓	✓	✓	✓	✓
Reactive power factors, phase, total	✓	✓	✓	✓	✓
COS ϕ + sign, phase, total	✓	✓	✓	✓	✓
SIN ϕ + sign, phase, total	✓	✓	✓	✓	✓
COS ϕ + sign of reactive distortion power, phase, total	✓	✓	✓	✓	✓
Capacitive-, inductive scaling factor of COS ϕ (-1..0..+1) :	✓	✓	✓	✓	✓
tan ϕ (L+), Phase, total on imported inductive reactive energy	✓		✓	✓	✓
tan ϕ (C-),Phase, total on exported capacitive reactive energy	✓		✓	✓	✓
tan ϕ (L-),Phase, total on exported inductive reactive energy	✓		✓	✓	✓
tan ϕ (C+),Phase, total on imported capacitive reactive energy	✓		✓	✓	✓
Triggered interval mean active power, phase					
Triggered interval mean active power, total					
Triggered interval mean reactive power, phase					
Triggered interval mean reactive power, total					


Time interval temperature & RCM	10/12T	150/180T	10 min	2 h	1 s	N* s	N* min
Temperature					✓	✓	✓
Residual current RCM	✓	✓	✓	✓			
Residual current FCM	✓	✓	✓	✓			
Leakage conductances, capacitances	✓	✓	✓	✓			

2.3 Oscilloscopic recorder

Sampling rate: 40.96 kHz / 10,24kHz / 1.024kHz

Max. Record length: 4sec (40,96kHz) / 16sec (10,24kHz) / 160sec (1.024kHz)

Quantities	
3-wire system	4-wire system
phase – ground voltages	phase –neutral voltages
residual voltage	neutral – ground voltage
phase – phase voltages	
phase currents	
total current	neutral current




2.4 Half cycle recorder

Recording rate: ~10 ms (50 Hz) or ~8.333 ms (60 Hz)

Max. Record length: 6 min (50 Hz) or 5 min (60 Hz)

Quantities
Power frequency
r.m.s. voltages
r.m.s. currents
Active power, phase
Reactive power, phase
Active power, total
Fundamental reactive power (displacement), total
Phase angle of fundamental apparent power, total
Voltage phasors (fundamental)
Current phasors (fundamental)
Positive-, negative-, zero sequence voltage phasors
Positive-, negative-, zero sequence current phasors



2.5 Recorder triggering

trigger quantity	lower	upper	step
RMS phase voltages (T/2)	✓	✓	✓
RMS phase-phase voltages (T/2)	✓	✓	✓
RMS residual/neutral-ground voltage (T/2)		✓	✓
Positive sequence voltage (T/2)	✓	✓	
Negative sequence voltage (T/2)		✓	
Zero sequence voltage (T/2)		✓	
Phase voltage phase (T/2)			✓
phase voltages wave shapes (wave shape filter)	+/- threshold		
phase-phase voltages wave shapes (wave shape filter)			
residual/neutral-ground voltage wave shape (wave shape filter)			
RMS phase currents (T/2)	✓	✓	✓
RMS total / neutral current (T/2)		✓	✓
Power frequency (T/2)	✓	✓	✓
Binary inputs (debounced)	rising, falling slope		
Command	external		

2.6 PQ Events

trigger quantity	lower	upper
Voltage dip (T/2)	✓	
Voltage swell (T/2)		✓
Voltage interruption (T/2)	✓	
Voltage rapid voltage change (T/2)	sliding average filter mean +/- threshold	
Voltage change (10min)	✓	✓
Voltage unbalance (10min)		✓
Mains signalling voltage (150/180T)		✓
Voltage harmonics (10min)		✓
Voltage THD (10min)		✓
Voltage short term flicker PST (10min)		✓
Voltage long term flicker PLT (10min)		✓
Power frequency (10s)	✓	✓

2.7 Online mode for direct readings

Measurement / Functions

Oscilloscopic recorder



Voltage and current harmonics $n=2..50$

Voltage and current interharmonics $n=0..49$

Voltage and current harmonics 2-9kHz


Frequency spectra up to 20 kHz of voltages and currents

Online streaming of all data classes and all measured values



Live data				
	L1	L2	L3	N
U	233.053 V	233.119 V	233.9 V	0.883 V
I	74.149 A	63.186 A	75.747 A	23.064 A
P	16.767 kW	14.385 kW	17.322 kW	48.394 kW
THD U	2.786 %	2.457 %	2.492 %	0 %
THD I	19.051 %	14.262 %	14.453 %	94.497 %
Frequency				
50.002 Hz				

Power				
	L1	L2	L3	Total
S	17.714 kVA	14.746 kVA	17.684 kVA	50.13 kVA
Q	4.232 kVAR	3.468 kVAR	3.755 kVAR	11.41 kVAR
P	17.201 kW	14.333 kW	17.281 kW	48.814 kW
D	3.317 kVAR	2.202 kVAR	2.613 kVAR	8.132 kVAR
PF	0.971	0.972	0.977	0.974
cos(phi1)	0.989 cap.	0.983 cap.	0.988 cap.	0.987 cap.



3. Order specifications *PQI-DE*

For determining the smart code ordering details:

- Only one unit can be ordered for codes with the same capital letter.

Characteristic	Code
Power Quality Interface and fault recorder <ul style="list-style-type: none"> ● 4 voltage converters, 4 current transformers ● In accordance with DIN EN 50160 and IEC 61000-4-30 (Class A) – Ed 3 ● 8 digital inputs ● 4 relay outputs ● WinPQ Lite software for PQI-DE 	<i>PQI-DE</i>
Supply voltage (operation range) <ul style="list-style-type: none"> ● AC 90 V..110 V..264 V or DC 108 V..220 V..350 V ● DC 18 V...60 V...75 V ● DC 40 V...160V 	H1 H2 H3
Voltage inputs <ul style="list-style-type: none"> ● 100V 2MOhm 25pF (150V CATII) ● 100V / 400 V / 690V 10MOhm 25pF (300V CAT IV) ● 3,25V 2MOhm 50pF for small signal transducer IEC 61869-11 (SELV) 	E1 E2 E3
Current inputs <ul style="list-style-type: none"> ● 4 current inputs for metering circuit 1A/5A (range 10A) ● 4 current inputs for protection circuit 1A/5A (range 100A) ● 4 current inputs for Rogowski Coils (330mV input) ● 4 AC current inputs for current clamps (0,5V input AC converter) ● 4 DC current inputs for current clamps (5V input DC converter) 	C30 C31 C40 C44 C45
Binary inputs <ul style="list-style-type: none"> ● 8 programmable binary inputs (AC/DC 48..250V) ● 8 programmable binary inputs (DC 10..48V) 	M1 M2
Option IEC 61000-4-7 (40.96 kHz sampling) <ul style="list-style-type: none"> ● 10.24 kHz sampling; without 2 kHz to 20kHz measurement ● Frequency measurement of voltage and current from 2 kHz to 20kHz according IEC61000-4-7; 40.96 kHz sampling oscilloscope recorder 	B0 B1
Option communication protocol <ul style="list-style-type: none"> ● Modbus RTU & TCP ● IEC 60870-5-104 (RJ45) ● IEC 61850 (RJ45) ● Modbus Master (Option P3) für I-Sense Strom Abgangsmessung und Aufzeichnung 	P0 P1 P2 P3
Option RCM <ul style="list-style-type: none"> ● Without Residual current monitor RCM (5th current input) ● Residual current monitor RCM (5th current input) (Firmware V2.2) 	D0 D1
Option Data format <ul style="list-style-type: none"> ● Without PQDIF export function according to IEEE1159-3 ● With PQDIF export function according to IEEE1159-3 Data transfer via feature P2 - IEC61850 / MMS 	F0 F1

Operating instructions

- German
- English

G1
G2

3.1 Software for PQI-DE

Software WebPQ	Code
<p>WebPQ database software incl. PostgreSQL database for fully automated processing and evaluation of power quality data in your IT environment! The basic versions always include 3 units – expandable via add-on.</p> <p>Range of functions</p> <ul style="list-style-type: none"> – Automated readout of measurement data from the PQI-LV / PQI-DA smart and PQI-DE devices via SSH and CCCI interface – Web server for visualisation of measurement data and fault records in level - time diagrams / histograms / bar charts / pointer diagrams / ITIC / and more – Responsive live data display of one or more devices in parallel – Automated alarm management in the event of faults – Automated reports in accordance with EN50160 and IEC61000-2-2 / IEC61000-2-4 / IEC61000-2-12 switchable to up to 65 standard templates – Parameterisation and management of the measuring devices via the web server – IT security via a comprehensive user rights management system with audit logging, password policies, etc. – Visualisation of measurement data from PQI-D and PQI-DA devices – Integration of WinPQ in WebPQ to support PQI-D's – CSV and Comtrade export functionality 	
<p>WebPQ Licences</p> <ul style="list-style-type: none"> ● WebPQ Basic incl. 3 units for a maximum of 30 units with basic functionality ● WebPQ Professional incl. 3 units for up to a maximum of 100 units with professional functionality ● WebPQ Enterprise incl. 3 units for systems > 100 units with enterprise functionality 	<p>L.900.9266.10</p> <p>L.900.9266.20</p> <p>L.900.9266.30</p>
<ul style="list-style-type: none"> ● WebPQ FirstOrder 10 Units ● WebPQ FirstOrder 30 Units ● WebPQ FirstOrder 50 Units ● WebPQ FirstOrder 100 Units ● WebPQ FirstOrder 500 Units ● WebPQ FirstOrder 1000 Units 	<p>L.900.9266.1010</p> <p>L.900.9266.1025</p> <p>L.900.9266.2050</p> <p>L.900.9266.2100</p> <p>L.900.9266.3500</p> <p>L.900.9266.3599</p>
<ul style="list-style-type: none"> ● WebPQ Add on "Fleetmanagement" – ● WebPQ Add on "Nequal-Export" 	<p>L.900.9265.32</p> <p>L.900.9265.34</p>
<p>Extension of the number of units</p> <ul style="list-style-type: none"> ● WebPQ Addon 10 Units ● WebPQ Addon 50 Units ● WebPQ Addon 100 Units 	<p>L.900.9266.60</p> <p>L.900.9266.61</p> <p>L.900.9266.62</p>
<p>Maintenance Agreements</p> <ul style="list-style-type: none"> ● WebPQ Annual maintenance agreement ● WebPQ One-time maintenance agreement 	<p>L.900.9066.10.01</p> <p>L.900.9066.10.02</p>

3.2 PQI-DE Accessories

The accessories for the *PQI-DE* can be accessed directly via the link below or by scanning the QR code.

Link:

www.a-eberle.de/pqsys-accessories

QR-Code:



► **Note:** When selecting the accessories, the corresponding hardware properties must be observed.

A. Eberle GmbH & Co. KG

Frankenstraße 160
D-90461 Nuremberg

Tel.: +49 (0) 911 / 62 81 08-0

Fax: +49-(0)911-62 81 08 99

E-mail: info@a-eberle.de

<http://www.a-eberle.de>

Presented by:

Copyright 2022 by A. Eberle GmbH & Co. KG

Subject to change without prior notice.

Version: 2/24/2025 2:18 PM